

U



SUBDIVISION ASSESSMENT  
HEALTH PROTECTION BRANCH

ÉVALUATION DE LOTISSEMENT  
DIRECTION DE LA PROTECTION DE LA SANTÉ

SUBDIVISION KINGSTON CLIFFS PARCELS 1045 NUMBER OF LOTS 41  
 SUBDIVISION PARISH OF KINGSTON SURVEYOR HUGHES SURVEYS  
 OWNER/AGENT ENERGREEN HOMESITES INC TELEPHONE (506) 848-1780  
 DATE OF ASSESSMENT 18 June 2010 DATE OF PLAN 30 March 2010  
 IS VARIANCE REQUIRED  YES  NO

VISUAL INSPECTION		INSPECTION VISUELLE	
ACCEPTABLE ACCEPTÉ	UNACCEPTABLE NON ACCEPTÉ	ACCEPTABLE ACCEPTÉ	UNACCEPTABLE NON ACCEPTÉ
LOT AREA SURFACE DU LOT	<input checked="" type="checkbox"/>	SET BACKS FROM PROPERTY RECL. D'IMMÉDIATÉ	<input checked="" type="checkbox"/>
LOT WIDTH LARGEUR DU LOT	<input checked="" type="checkbox"/>	SET BACKS FROM STREETS, LAPILLAS LACINGS, ETC. RECL. DES VOIES, RECL. PUNÉRAIRES	<input checked="" type="checkbox"/>
LOT DEPTH PROFONDEUR DU LOT	<input checked="" type="checkbox"/>		
IS THE LAND WITHIN THE WATERSHED OF A COMMUNAL WATER SUPPLY LE TERRAIN EST-IL À L'INTÉRIEUR D'UN BASSIN HYDROGRAPHIQUE COMMUNAUTAIRE		YES/OUI	NO/NON
IS THE LAND SUBJECT TO FLOODING LE TERRAIN EST-IL SUJET AUX INONDATIONS		<input type="checkbox"/>	<input checked="" type="checkbox"/>
ESTIMATION OF SLOPE ÉVALUATION DE LA PENTE		<10%	10-20% <u>&gt;20%</u>
SOIL PROFILE		PROFIL DU SOL	

NUMBER OF SOIL TEST HOLES REQUESTED (SHOW LOCATION ON PLAN)  
 NOMBRE DE TROUS REQUIS (MONTRER ENDROITS SUR PLAN) 1 (see Note) DATE REQUESTED 14 June 2010  
 DATE REQUISE

SOIL TYPE GRAVEL / CLAY MIX  
 SORTIE DE SOL  
 DEPTH OF WATER TABLE OR DEPTH OF BEDROCK  
 RAFFLE PIÉZOMÉTRIQUE, PROFONDEUR OR ROC PROFONDEUR 0.3m OU 1.5m

NUMBER (SHOW EXACT LOCATION ON PLAN) NOMBRE (MONTRER ENDROITS SUR PLAN)	AVERAGE RATE INFILTRATION MOYENNE	DATE CONDUCTED DATE
SUMMARY	RÉSUMÉ	

	NUMBER/ NOMBRE	LOT NUMBERS/ NUMÉROS DE LOT	MAXIMUM RECOMMENDED LITRES/DAY FOR EACH LOT/ NOMBRE MAXIMUM DE LITRES/JOUR RECOMMANDÉ, POUR CHAQUE LOT
LOTS ACCEPTABLE LOTS ACCEPTÉS	<u>All</u>	<u>01-41</u>	
*LOTS REQUIRING MODIFICATION *LOTS DEVANT ÊTRE MODIFIÉS	<u>41</u>	<u>01-41</u>	
*LOTS REQUIRING VARIANCE *LOTS DEMANDANT DÉROGATION	<u>0</u>		
*LOTS UNACCEPTABLE *LOTS REPUSÉS	<u>0</u>		

\*SPECIFIC COMMENTS  
 \*COMMENTAIRES All lots range in size from 4000m<sup>2</sup> to 1 hectare. There are 3 parcels of land on this property which have been delineated by the Dept of Environment. All set back distances have also been approved. All future septic systems for this proposed subdivision will require 3'-4' foot mounds. All lots meet or exceed the minimum requirement of 1365 litres/day (3 bedrooms home)  
21 June 2010

[Signature]  
 PUBLIC HEALTH INSPECTOR / INSPECTEUR EN SANTÉ PUBLIQUE

DATE

MEDICAL OFFICER OF HEALTH / MÉDECIN HYGIENISTE RÉGIONAL  
 (IF VARIANCE REQUIRED) (SI DÉROGATION REQUISE)